



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: IECEx FTZU 18.0018

Issue No: 0

Certificate history:

Issue No. 0 (2019-01-31)

Status: **Current**

Page 1 of 3

Date of Issue: **2019-01-31**

Applicant: **Van Houcke NV**
Vlamingveld 32
8490 Jabbeke
Belgium

Equipment: **Three-phase asynchronous motors 1TE1531-..., 1TE1521-..., 1TE1533..., 1TE1523...
frame size:-0C..., -0D..., -0E... (71 to 90)**

Optional accessory:

Type of Protection: **Explosion protection "nA" and "tc"**

Marking:

Ex tc IIIB T120°C Dc
or
Ex nA IIC T3 Gc
or
Ex nA IIB T3 Gc
or
Ex nA IIC T3 Gc and Ex tc IIIB T120°C Dc

*Approved for issue on behalf of the IECEx
Certification Body:*

Dipl. Ing. Lukáš Martinák

Position:

Head of Certification Body

*Signature:
(for printed version)*

Date:

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

**Fyzikálne technický zkušební ústav
(Physical -Technical Testing Institute)
Pikartská 7, 71607 Ostrava - Radvanice
Czech Republic**





IECEX Certificate of Conformity

Certificate No: IECEX FTZU 18.0018

Issue No: 0

Date of Issue: 2019-01-31

Page 2 of 3

Manufacturer: **Van Houcke NV**
Vlamingveld 32
8490 Jabbeke
Belgium

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2011 Explosive atmospheres - Part 0: General requirements
Edition:6.0

IEC 60079-15 : 2010 Explosive atmospheres - Part 15: Equipment protection by type of protection "n"
Edition:4

IEC 60079-31 : 2013 Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"
Edition:2

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

[CZ/FTZU/ExTR18.0023/00](#)

Quality Assessment Report:

[GB/CML/QAR18.0038/00](#)



IECEX Certificate of Conformity

Certificate No: IECEx FTZU 18.0018

Issue No: 0

Date of Issue: 2019-01-31

Page 3 of 3

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The electric motors types 1TE1521-..., 1TE1523-... are designed for application in explosive dust atmosphere and have explosion protection by enclosure "tc".

The electric motors types 1TE1531-..., 1TE1533-... are designed for application in explosive gas atmosphere with "nA" type of protection. These motors are alternatively designed to match requirements of both types of protection "nA" and "tc".

Electric motors are low voltage asynchronous squirrel cage motors. They have surface cooling with external fan fastened on shaft of electric motor.

The enclosures of electric motor and terminal box are made of cast iron. The external fans are made of aluminium alloy. The fan covers are made of steel plates. The shaft is fastened in roller bearings. The squirrel cage is made from die-cast of aluminium.

The connection design of separate parts and used sealing materials ensure degree of protection provided by cover minimally IP 55. For sealing of contact surfaces of electric motor body and terminal box and detachable parts of terminal box are used gaskets or special profile silicone sealing. The shaft sealing of electric motor in enclosure provides: a DIN3760 shaft sealing ring. Material of these sealing rings is HNBR. The flange motors designed for assembly on gear boxes use a radial shaft sealing for oil sealing.

The electric connection is made in terminal box that is equipped with connection terminals. Entry of cable into the terminal box provide Ex equipment cable glands.

The electric motor windings could be optionally equipped with temperature sensors PTC, KTY, or resistance temperature sensors. Inside of electric motor can be also installed heating units for prevention of wet air condensation when the electric motor is switched off.

Electrical parameters of basic versions of network supply electric motors are given in Attachment to this certificate.

The electric motors type 1TE1531-..., 1TE1521-..., 1TE1533-..., 1TE1523-... can be alternatively operated with frequency converter type SINAMICS G120, S120, G180 or comparable converters described in the manufacturer documentation. The motor used in frequency converter supply windings is equipped with temperature sensors PTC. Nominal cut-off temperature of the PTC is +130°.

SPECIFIC CONDITIONS OF USE: NO

Annex:

[Attachment_IECE_FTZU_18_0018_00.pdf](#)



Attachment to Certificate of Conformity
IECEx FTZU 18.0018 issue No.: 0



Applicant: **Van Houcke NV**
Address: **Vlamingveld 32, 8490 Jabbeke, Belgium**
Equipment: **Three-phase asynchronous motors types:
1TE1531-..., 1TE1521-..., 1TE1533..., 1TE1523...
frame size: -0C..., -0D..., -0E... (71 to 90)**

General technical parameters:

Ambient temperature: $-20^{\circ}\text{C} \leq T_a \leq +40^{\circ}\text{C}$, or
 $-40^{\circ}\text{C} \leq T_a \leq +40^{\circ}\text{C}$ or
 $-20^{\circ}\text{C} \leq T_a \leq +60^{\circ}\text{C}$ with decreased output power of electrical motor,
 $-40^{\circ}\text{C} \leq T_a \leq +60^{\circ}\text{C}$ with decreased output power of electrical motor.

Motors supplied by voltage with frequency 50Hz:

Voltage: from 200 V to 690 V, voltage tolerances: $\pm 10\%$
Outputs: from 0,09 kW to 2,2 kW
Duty type: S1
Number of poles: 2, 4, 6, 8

Motors supplied by voltage with frequency 60 Hz:

Voltage: from 220V to 690 V, voltage tolerances: $\pm 10\%$
Outputs: from 0.105 kW to 2.55 kW
Duty type: S1
Number of poles: 2, 4, 6, 8

General technical parameters of motors operated with frequency converter:

The motors of the above mentioned models series cover the following max. rated data:

Rated voltage: max. 690V $\pm 10\%$ (input of converter)
Outputs: max. 2,55 kW
Duty type: S9
Frequency: from 2 Hz to 100 Hz

Motors for converter supply will be equipped with second name plate with converter and load dates.



Attachment to Certificate of Conformity
IECEx FTZU 18.0018 issue No.: 0



Applicant: **Van Houcke NV**
Address: **Vlamingveld 32, 8490 Jabbeke, Belgium**
Equipment: **Three-phase asynchronous motors types:
1TE1531-..., 1TE1521-..., 1TE1533..., 1TE1523...
frame size: -0C..., -0D..., -0E... (71 to 90)**

Rated parameters of basic versions of electric motors **Ex nA IIC T3 Gc, Ex tc IIIB T120°C Dc:**

| Type | 400 V 50Hz | | | 460 V 60Hz | | |
|--------------|-------------------------------|-------------|----------------------------|---------------------------|-------------|----------------------------|
| | Output [kW] | Current [A] | Speed [min ⁻¹] | Output [kW] | Current [A] | Speed [min ⁻¹] |
| 2-poles | (3000 min ⁻¹) IE2 | | | (3600 min ⁻¹) | | |
| 1TE15.1-0CA2 | 0,37 | 0,95 | 2770 | 0,43 | 0,93 | 3370 |
| 1TE15.1-0CA3 | 0,55 | 1,34 | 2780 | 0,63 | 1,34 | 3380 |
| 1TE15.1-0DA2 | 0,75 | 1,67 | 2805 | 0,86 | 1,7 | 3410 |
| 1TE15.1-0DA3 | 1,1 | 2,4 | 2835 | 1,27 | 2,3 | 3430 |
| 1TE15.1-0EA0 | 1,5 | 3,15 | 2885 | 1,75 | 3,1 | 3480 |
| 1TE15.1-0EA4 | 2,2 | 4,5 | 2890 | 2,55 | 4,35 | 3485 |

| Type | 400 V 50Hz | | | 460 V 60Hz | | |
|--------------|-------------------------------|-------------|----------------------------|---------------------------|-------------|----------------------------|
| | Output [kW] | Current [A] | Speed [min ⁻¹] | Output [kW] | Current [A] | Speed [min ⁻¹] |
| 4-poles | (1500 min ⁻¹) IE2 | | | (1800 min ⁻¹) | | |
| 1TE15.1-0CB2 | 0,25 | 0,76 | 1395 | 0,29 | 0,75 | 1695 |
| 1TE15.1-0CB3 | 0,37 | 1,02 | 1380 | 0,43 | 1,04 | 1680 |
| 1TE15.1-0DB2 | 0,55 | 1,39 | 1440 | 0,63 | 1,42 | 1735 |
| 1TE15.1-0DB3 | 0,75 | 1,79 | 1440 | 0,86 | 1,82 | 1740 |
| 1TE15.1-0EB0 | 1,1 | 2,5 | 1425 | 1,27 | 2,45 | 1725 |
| 1TE15.1-0EB4 | 1,5 | 3,3 | 1435 | 1,75 | 3,3 | 1730 |



Attachment to Certificate of Conformity
IECEX FTZU 18.0018 issue No.: 0



Applicant: **Van Houcke NV**
Address: **Vlamingveld 32, 8490 Jabbeke, Belgium**
Equipment: **Three-phase asynchronous motors types:
1TE1531-..., 1TE1521-..., 1TE1533..., 1TE1523...
frame size: -0C..., -0D..., -0E... (71 to 90)**

Rated parameters of basic versions of electric motors **Ex nA IIC T3 Gc, Ex tc IIIB T120°C Dc** - continue:

| Type | 400 V 50Hz | | | 460 V 60Hz | | |
|--------------|-------------------------------|-------------|----------------------------|---------------------------|-------------|----------------------------|
| | Output [kW] | Current [A] | Speed [min ⁻¹] | Output [kW] | Current [A] | Speed [min ⁻¹] |
| 6-poles | (1000 min ⁻¹) IE2 | | | (1200 min ⁻¹) | | |
| 1TE15.1-0CC2 | 0,18 | 0,68 | 875 | 0,21 | 0,72 | 1075 |
| 1TE15.1-0CC3 | 0,25 | 0,84 | 870 | 0,29 | 0,87 | 1070 |
| 1TE15.1-0DC2 | 0,37 | 1,14 | 925 | 0,43 | 1,22 | 1125 |
| 1TE15.1-0DC3 | 0,55 | 1,65 | 935 | 0,63 | 1,76 | 1135 |
| 1TE15.1-0EC0 | 0,75 | 2,05 | 935 | 0,86 | 2,1 | 1135 |
| 1TE15.1-0EC0 | 0,75 | 1,95 | 935 | 0,86 | 2,05 | 1135 |
| 1TE15.1-0EC4 | 1,1 | 2,9 | 935 | 1,27 | 3,05 | 1135 |

| Type | 400 V 50Hz | | | 460 V 60Hz | | |
|--------------|--------------------------|-------------|----------------------------|--------------------------|-------------|----------------------------|
| | Output [kW] | Current [A] | Speed [min ⁻¹] | Output [kW] | Current [A] | Speed [min ⁻¹] |
| 8-poles | (750 min ⁻¹) | | | (900 min ⁻¹) | | |
| 1TE15.1-0CD2 | 0,09 | 0,5 | 630 | 0,11 | 0,53 | 790 |
| 1TE15.1-0CD3 | 0,12 | 0,65 | 640 | 0,14 | 0,69 | 795 |
| 1TE15.1-0DD2 | 0,18 | 0,93 | 690 | 0,21 | 0,97 | 840 |
| 1TE15.1-0DD3 | 0,25 | 1,3 | 705 | 0,29 | 1,27 | 855 |
| 1TE15.1-0ED0 | 0,37 | 1,34 | 675 | 0,43 | 1,33 | 830 |
| 1TE15.1-0ED4 | 0,55 | 1,74 | 665 | 0,63 | 1,77 | 820 |



Attachment to Certificate of Conformity
IECEX FTZU 18.0018 issue No.: 0



Applicant: **Van Houcke NV**
Address: **Vlamingveld 32, 8490 Jabbeke, Belgium**
Equipment: **Three-phase asynchronous motors types:
1TE1531-..., 1TE1521-..., 1TE1533..., 1TE1523...
frame size: -0C..., -0D..., -0E... (71 to 90)**

Rated parameters of basic versions of electric motors **Ex nA IIC T3 Gc, Ex tc IIIB T120°C Dc** - continue:

| Type | 400 V 50Hz | | | 460 V 60Hz | | |
|--------------|-------------------------------|-------------|----------------------------|---------------------------|-------------|----------------------------|
| | Output [kW] | Current [A] | Speed [min ⁻¹] | Output [kW] | Current [A] | Speed [min ⁻¹] |
| 2-pole | (3000 min ⁻¹) IE3 | | | (3600 min ⁻¹) | | |
| 1TE15.3-0CA2 | 0,37 | 0,95 | 2850 | 0,43 | 0,97 | 3445 |
| 1TE15.3-0CA3 | 0,55 | 1,34 | 2850 | 0,63 | 1,35 | 3450 |
| 1TE15.3-0DA2 | 0,75 | 1,56 | 2850 | 0,86 | 1,63 | 3450 |
| 1TE15.3-0DA3 | 1,1 | 2,25 | 2885 | 1,27 | 2,25 | 3480 |
| 1TE15.3-0EA0 | 1,5 | 3 | 2910 | 1,75 | 2,95 | 3510 |
| 1TE15.3-0EA4 | 2,2 | 4,2 | 2910 | 2,55 | 4,2 | 3510 |

| Type | 400 V 50Hz | | | 460 V 60Hz | | |
|--------------|-------------------------------|-------------|----------------------------|---------------------------|-------------|----------------------------|
| | Output [kW] | Current [A] | Speed [min ⁻¹] | Output [kW] | Current [A] | Speed [min ⁻¹] |
| 4-pole | (1500 min ⁻¹) IE3 | | | (1800 min ⁻¹) | | |
| 1TE15.3-0CB2 | 0,25 | 0,68 | 1395 | 0,29 | 0,69 | 1695 |
| 1TE15.3-0CB3 | 0,37 | 0,99 | 1410 | 0,43 | 0,99 | 1710 |
| 1TE15.3-0DB2 | 0,55 | 1,26 | 1440 | 0,63 | 1,25 | 1740 |
| 1TE15.3-0DB3 | 0,75 | 1,75 | 1450 | 0,86 | 1,72 | 1750 |
| 1TE15.3-0EB0 | 1,1 | 2,4 | 1440 | 1,27 | 2,35 | 1740 |
| 1TE15.3-0EB4 | 1,5 | 3,15 | 1445 | 1,75 | 3,15 | 1740 |



Attachment to Certificate of Conformity
IECEX FTZU 18.0018 issue No.: 0



Applicant: **Van Houcke NV**
Address: **Vlamingveld 32, 8490 Jabbeke, Belgium**
Equipment: **Three-phase asynchronous motors types:
1TE1531-..., 1TE1521-..., 1TE1533..., 1TE1523...
frame size: -0C..., -0D..., -0E... (71 to 90)**

Rated parameters of basic versions of electric motors **Ex nA IIC T3 Gc, Ex tc IIIB T120°C Dc** - continue:

| Type | 400 V 50Hz | | | 460 V 60Hz | | |
|--------------|-------------------------------|-------------|----------------------------|---------------------------|-------------|----------------------------|
| | Output [kW] | Current [A] | Speed [min ⁻¹] | Output [kW] | Current [A] | Speed [min ⁻¹] |
| 6-pole | (1000 min ⁻¹) IE3 | | | (1200 min ⁻¹) | | |
| 1TE15.3-0CC2 | 0,18 | 0,59 | 885 | 0,21 | 0,57 | 1085 |
| 1TE15.3-0CC3 | 0,25 | 0,76 | 885 | 0,29 | 0,74 | 1085 |
| 1TE15.3-0DC2 | 0,37 | 1,1 | 940 | 0,43 | 1,09 | 1140 |
| 1TE15.3-0DC3 | 0,55 | 1,53 | 935 | 0,63 | 1,44 | 1135 |
| 1TE15.3-0EC0 | 0,75 | 1,96 | 945 | 0,86 | 1,87 | 1140 |
| 1TE15.3-0EC4 | 1,1 | 2,85 | 940 | 1,27 | 3,05 | 1140 |